



Cape St Francis
Hankey
Humansdorp
Jeffreys Bay
Loerie
Oyster Bay
Patensie
St Francis Bay
Thornhill

Postal: PO Box 21, Jeffreys Bay, 6330
Tel: 042 200 2200 / 042 200 8300
Fax: 042 200 8606
Email: registry@kouga.gov.za
Website: www.kouga.gov.za

Attention : To All tenderers

DATE : 12 JULY 2022

BID No. : 96/2022
HANKEY SANITATION UPGRADE (PHASE 3) :
CONSTRUCTION OF NEW AND UPGRADING OF EXISTING
SEWER PUMP STATIONS IN HANKEY
(CIVIL, STRUCTURAL, MECHANICAL & ELECTRICAL)

“ADDENDUM NO.2”

This “Addendum No.2” should be read and implemented in addition to the Tender Document listed in the Schedule of Documents. Any tender submitted will be deemed to be in accordance with the following instructions :

- Addendum Number 2

Yours faithfully,

MR J DU TOIT



Cape St Francis
Hankey
Humansdorp
Jeffreys Bay
Loerie
Oyster Bay
Patensie
St Francis Bay
Thornhill

Postal: PO Box 21, Jeffreys Bay, 6330
Tel: 042 200 2200 / 042 200 8300
Fax: 042 200 8606
Email: registry@kouga.gov.za
Website: www.kouga.gov.za

Attention: Mr Jacques du Toit
Kouga Local Municipality
Email : tenders@kouga.gov.za and jdutoit@kouga.gov.za

BID No. : 96/2022
HANKEY SANITATION UPGRADE (PHASE 3) :
CONSTRUCTION OF NEW AND UPGRADING OF EXISTING
SEWER PUMP STATIONS IN HANKEY
(CIVIL, STRUCTURAL, MECHANICAL & ELECTRICAL)

“ADDENDUM NO.2”

This is to confirm that we have received the following notice per e-mail:

1. ADDENDUM NO.2

Pages inclusive of the cover page, this page and the Minutes are : 5 pages

TENDERER : _____

REPRESENTATIVE: _____

DATE: _____

SIGNATURE: _____

1. **NOTE:** Please complete and sign this “Confirmation or Receipt” of “ADDENDUM NO.2” and e-mail to the above two (2) addresses. Also attached this page to the Tender Document, Schedule 19 of the Returnable Schedules (pg 68 of 181).

Failure to sign and attach this “Addendum No.2” to the Tender Document will result in the tender being regarded as Non-Responsive.

ADDENDUM NO.2

BID No. : 96/2022 HANKEY SANITATION UPGRADE (PHASE 3) : CONSTRUCTION OF NEW AND UPGRADING OF EXISTING SEWER PUMP STATIONS IN HANKEY (CIVIL, STRUCTURAL, MECHANICAL & ELECTRICAL)

The following amendments must be made to the original Tender Document. Failure to include these changes and to price the revised Pricing Schedules accordingly, may lead to disqualification of the submitted Bid.

Tenderers are to note that the Kouga Local Municipality has agreed to extend the “Tender Closing Date” for above tender, with 7-days, from 18 July 2022, to 25 July 2022.

A : Questions & Answers :

Q1 : Page 12 of the tender data refers to a “Sub-contractor Agreement” to be submitted with the Tender. Is this a requirement only for subcontractors that do not fall into the SMME category?

A1 : Correct. Sub-Contract Agreement/s must be in place and submitted with the Tender Submission - this is not for “Material or Plant suppliers”, but is mainly applicable to a Sub-Contractor who will execute an actual part of the “Work Scope”, eg : a Civil Contractor, who will sub-contract all electrical works to a Specialist Electrical Company to design and build the electrical control panels (MCC), etc.

This Sub-contract agreement is also NOT applicable at Tender Stage, to any SMME sub-contractors, and the names / municipal data base of SMME sub-contractors will only be issued to the Primary Contractor upon Tender Award.

Q2 : Page 35, Schedule 12 the “Index” (heading) for “Experience & Qualifications of Key Personnel” differs from page 57, Schedule 12 of the Returnable Schedules. Please confirm the exact Key Personnel required, to submit CV & certificates accordingly.

A2 : In order to avoid confusion, please delete the “2x” before the “Construction Managers” on the Index / heading on page 35.

There are **6x minimum required Key Personnel** required for this Contract as follows, which should all appear on the Tenderer’s Organogram, to be submitted with the tender submission (obviously the Tenderer may at Tender Stage allow for and price accordingly, for more Key Personnel if deemed necessary) :

1. Part-Time **Contract Manager** (typically Head-Office Based) – see **Returnable Schedule 12A**. Costs should typically be tendered under Pay Item 1.2.17
2. Full Time **Construction Manager** (**Returnable Schedule 12B** / Pay Item 1.2.16 a)
3. Full Time **Site Agent - Civil or Structural** (No Returnable Schedule / Pay Item 1.2.16 b)
4. Part-Time **Site Agent – Electrical** (**Returnable Schedule 12C** / Pay Item 1.2.16 c)
5. Full Time **SMME Manager** (No returnable Schedule, Pay Item 1.2.16 d)
6. Full Time **Construction Safety Officer** (**Returnable Schedule 12D** / Pay Item 1.7.4)

The **scoring** of “Functionality Points” however, shall only be based on four (4x) Key Persons, as per the Returnable Schedules – refer to table in clause F2.1.4.3, on page 11 & 12, for which CV’s and Qualification certificates are required.

(Note, although no “Functionality Points” will be allocated / scored for the SMME Manager, this position also requires a dedicated Full-Time Key person, and Pay Item 1.2.16 d) must therefore be priced accordingly.

Q3 : Pay Item refers to Polypropylene liners (250 micron). Our suppliers confirmed that the minimum thickness available is 500 micron. Please confirm.


A3 : We will accept both 250 micron liners, and in the instance where this is not available from your supplier, you may price on 500 micron liners, and note that accordingly in your tender. However, we do require 2 liners to form a slip joint.

Q4 : There are no details on Tender Drw 5024-PH3-C310, showing the “anchor trenches” of the Polypropylene lining or the water-tightness installation of inlet or outlet pipes through the linings. Please provide details.

A4 : Provision was made on above drawing for a “cut-off” concrete toe at the Top Level of the Concrete Detention Pond, which will accommodate and serve as the anchor trench of the Polypropylene lining. Construction details will be provided on the set of Construction Drawings. Any omitted or additional items and applicable costs, will be addressed with a Variation Order during Construction Stage, as necessary.

END OF ADDENDUM NO.2

Addendum No.2 signed off by :



Mr J du Toit

and



Mr L Landu (SCM)